

CERTIFICATE OF COMPLIANCE

Certificate Number 20180118-E493186
Report Reference E493186-20180116
Issue Date 2018-JANUARY-18

Issued to: BIMED TEKNIK ALETLER SAN TIC A S
BEYLIKDUZU MEVKII
SS BAKIR VE PIRINC SAN
ORKIDE CD NO 15
34524 ISTANBUL TURKEY


This is to certify that representative samples of CONDUIT FITTINGS FOR USE IN ZONE CLASSIFIED HAZARDOUS LOCATIONS
See Next Page

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: See Next Page
Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20180118-E493186
Report Reference E493186-20180116
Issue Date 2018-JANUARY-18

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Models:

USL - Fittings for use in Class I, Zone 1, AEx d IIC Gb, AEx e IIC Gb; Zone 21, AEx tb IIIC Db Hazardous Locations.

Hexagonal head metallic blind stops, thread sizes M16 to M110 metric: Cat. No. B-TS, followed by 01 or 1 or 2 or 3 or 4 or 5 or 6 or 7 or 8 or 9 or 10 or 60 or 70 or 80 or 85, followed by M, followed by X or BN.

Allen head metallic blind stops, thread sizes 3/8 to 4 in. NPT: Cat. No. B-TS, followed by 01 or 1 or 2 or 3 or 4 or 5 or 6 or 7 or 8 or 9 or 10, followed by N, followed by X or BN.

Allen head metallic blind stops, thread sizes M16 to M110 metric: Cat. No. MB-TS, followed by 01 or 1 or 2 or 3 or 4 or 5 or 6 or 7 or 8 or 9 or 10 or 60 or 70 or 80 or 85, followed by M, followed by X or BN.

CNL - Fittings for use in Class I, Zone 1, Ex d IIC Gb, Ex e IIC Gb; Ex tb IIIC Db Hazardous Locations.

Hexagonal head metallic blind stops, thread sizes M16 to M110 metric: Cat. No. B-TS, followed by 01 or 1 or 2 or 3 or 4 or 5 or 6 or 7 or 8 or 9 or 10 or 60 or 70 or 80 or 85, followed by M, followed by X or BN.

Allen head metallic blind stops, thread sizes 3/8 to 4 in. NPT: Cat. No. B-TS, followed by 01 or 1 or 2 or 3 or 4 or 5 or 6 or 7 or 8 or 9 or 10, followed by N, followed by X or BN.


Allen head metallic blind stops, thread sizes M16 to M110 metric: Cat. No. MB-TS, followed by 01 or 1 or 2 or 3 or 4 or 5 or 6 or 7 or 8 or 9 or 10 or 60 or 70 or 80 or 85, followed by M, followed by X or BN.

USL - Fittings for use in Class I, Zone 1, AEx e IIC Gb; Zone 21, AEx tb IIIC Db Hazardous Locations.

Hexagonal head metallic blind stops, thread sizes 3/8 to 4 in. NPT: Cat. No. NB-TS, followed by 01 or 1 or 2 or 3 or 4 or 5 or 6 or 7 or 8 or 9 or 10, followed by N, followed by X or BN.

CNL - Fittings for use in Class I, Zone 1, Ex e IIC Gb; Ex tb IIIC Db Hazardous Locations.

Hexagonal head metallic blind stops, thread sizes 3/8 to 4 in. NPT: Cat. No. NB-TS, followed by 01 or 1 or 2 or 3 or 4 or 5 or 6 or 7 or 8 or 9 or 10, followed by N, followed by X or BN.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20180118-E493186
Report Reference E493186-20180116
Issue Date 2018-JANUARY-18

Standards:

Standard No. UL 60079-0, 6th Ed., Rev. 2017-10-20, Explosive atmospheres – Part 0: Equipment – General requirements

Standard No. UL 60079-1, 7th Ed., Issued 2015-09-18, Explosive Atmospheres – Part 1: Equipment Protection by Flameproof Enclosures “d”

Standard No. UL 60079-7, 5th Ed., Rev. 2017-04-21, Explosive Atmospheres – Part 7: Equipment protection by increased safety “e”


Standard No. UL 60079-31, 2nd Ed., Issued 2015-06-12, Explosive Atmospheres – Part 31: Equipment Dust Ignition Protection by Enclosure “t”

Standard No. CAN/CSA-C22.2 No. 60079-0:15, 3rd Ed., Issued 2015-10, Explosive atmospheres — Part 0: Equipment — General requirements

Standard No. CAN/CSA-C22.2 No. 60079-1:16, 3rd Ed., Issued 2016-05, Explosive atmospheres — Part 1: Equipment protection by flameproof enclosures “d”

Standard No. CAN/CSA C22.2 No. 60079-7:12, 1st Ed., Issued 2012-02, Explosive atmospheres — Part 7: Equipment protection by increased safety “e”

Standard No. CAN/CSA-C22.2 No. 60079-31:15, 2nd Ed., Issued 2015-10, Explosive atmospheres — Part 31: Equipment dust ignition protection by enclosure “t”



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

